

SHEBOYGAN WATER UTILITY

2018 Water Quality Analysis

Updated March 5, 2019

Explanation of units: since one gallon of water weighs 8.34 pounds, one million gallons of water weighs 8,340,000 pounds. When 8.34 pounds of a pure substance is added to one million gallons of water the concentration would be one part per million.

parts per million (ppm) = milligrams per liter (mg/L) = 1 in 1,000,000

parts per billion (ppb) = micrograms per liter (ug/L) = 1 in 1,000,000,000

parts per trillion (ppt) = nanograms per liter (ng/L) = 1 in 1,000,000,000,000

parts per quadrillion (ppq) = picograms per liter (pg/L) = 1 in 1,000,000,000,000,000

Just how small are these terms in other units?

Unit	<u>1 part per million</u>	<u>1 part per billion</u>	<u>1 part per trillion</u>	<u>1 part per quadrillion</u>
Length	1 inch in 16 miles	1 inch in 16,000 miles	1 inch in 16,000,000 miles	1 inch in 16,000,000,000 miles
Time	1 minute in 2 years	1 minute in 2,000 years	1 min. in 2,000,000 years	1 min. in 2,000,000,000 years
Money	1 cent in \$10,000	1 cent in \$10,000,000	1 cent in \$10,000,000,000	1 cent in \$10,000,000,000,000

Important Water Terms:

Maximum Contaminant Level (MCL): Highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCLG): Level of a contaminant in drinking water below which there is no known or expected risk to health.

Turbidity: A measure of the clarity of water reported in Neophelometric Turbidity Units (NTU's). Is just noticeable to the average person in excess of 5 NTU.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

No Standard (NS): The Environmental Protection Agency (EPA) has not determined standards for these substances.

Not Tested (NT): The constituent was not tested for.

Million Fibers per Liter (mfl): The measure of the presence of asbestos fibers that are longer than 10 micrometers.

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

MDL: Minimum detection level. Lowest amount that can be detected in the laboratory.

Not Applicable (NA): The test results vary with incoming water quality.

Results reported in less than (<) units indicate the amount of the chemical being tested for is "less than" the detection limit of the machines used to do the analysis.

<u>Physical</u>	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
Temperature	continuous	NS	NS	33 to 62 deg. F	33 to 64 deg. F
pH	daily	6.5 to 8.5	NS	average of 7.57	average of 8.22
Color	continuous	15 Units	NS	< 1 color unit	average of 5
Total Residue	Monthly	NS	NS	144 ppm	NA
Turbidity	continuous	0.30 ntu	NS	average of 0.031 NTU	average of 7.35 NTU
Conductivity	continuous	NS	NS	average of 147.7ns/cm @ 6.2 C°	average of 148.4ns/cm @ 6.2 C°

II Inorganic

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
Alkalinity, total CaCO3	daily	NS	NS	average of 100 ppm	average of 108 ppm
Aluminum (Al)	2006	.05-.2 ppm	NS	.074 ppm	NT
Antimony (Sb)	2018	6,000 ppt	6,000 ppt	170 ppt	NT
Arsenic (As)	2018	10,000 ppt	n/a	<400 ppt	NT
Asbestos, Total	2003	7 mfl > 10 microns	7 mfl > 10 microns	<0.085	NT
Barium (Ba)	2018	2,000 ppb	2,000 ppb	19 ppb	NT
Beryllium (Be)	2018	4,000 ppt	4,000 ppt	<50 ppt	<300 ppt
Cadmium (Cd)	2018	5,000 ppt	5,000 ppt	<300 ppt	<200 ppt
Calcium (Ca)	2010	NS	NS	34,000 ppb	NT
Chloride (Cl), Total	1999	250,000 ppb	NS	11,000 ppb	NT
Chlorine, free Cl2	continuous	4,000 ppb	NS	ave. of 0.840 ppm	ND
Chromium (Cr), Total	2018	100,000 ppt	100,000 ppt	570 ppt	NT
Copper (Cu)	2011	1,300 ppb	1,300 ppb	<20 ppb	NT
Cyanide, Total	1999	200 ppb	200 ppb	<10 ppb	NT
Fluoride (F)	continuous	4 ppm	4 ppm	0.72 ppm	0.15 ppm
Foaming Agents (MBAS)	2003	500 ppb	NS	<200 ppb	NT
Hardness, Total as CaCO3	monthly	NS	NS	155 ppm	NT
Iron (Fe)	1999	300 ppb	NS	<100 ppb	NT
Lead (Pb)	2017	15 ppb	0	<1.0 ppb	NT
Magnesium (Mg), Total	1999	NS	NS	11,000 ppb	NT
Manganese (Mn)	1999	50,000 ppt	NS	600 ppt	NT
Mercury (Hg)	2018	2,000 ppt	2,000 ppt	<40 ppt	<100 ppt
Nickel (Ni)	2018	100,000 ppt	NS	500 ppt	<1000 ppt
Nitrogen, NO3-N, Nitrate	2017	10,000 ppb	10,000 ppb	260 ppb	NT
Nitrates, NO3 + NO2 (Total)	2018	10,000 ppb	10,000 ppb	310 ppb	NT
Nitrogen, NO2-N, Nitrite	2017	1,000 ppb	1,000 ppb	<10 ppb	<10 ppb
Orthophosphate (as PO4)	Daily	NS	NS	670 ppb	NT
Selenium (Se)	2018	50 ppb	50 ppb	<2.0 ppb	<2 ppb
Silver (Ag)	1999	50 ppb	NS	<2.0 ppb	NT
Sodium (Na)	2018	500,000 ppb	NS	10,000 ppb	NT
Sulfate (SO4)	2018	250,000 ppb	NS	29,000 ppb	NT
Thallium (Tl)	2018	2,000 ppt	NS	<20 ppt	<200 ppt
Zinc (Zn)	1999	5,000,000 ppt	NS	<5000 ppt	NT

III Disinfection By-Products

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
Total Trihalomethanes (TTHMs) :		80,000 ppt		Average of 4 samples	No Standard
Bromodichloromethane	2018	NS	0 ppt	8,410 ppt	NT
Bromoform	2018	NS	0 ppt	<500 ppt	NT
Chloroform	2018	NS	0 ppt	14,750 ppt	NT
Dibromochloromethane	2018	NS	0 ppt	5,425 ppt	NT
		80,000 ppt		Total 28,850 ppt	No Standard
Total Haloacetic Acids (THAAs) :		60,000 ppt		Average of 4 samples	No Standard
Dibromoacetic Acid	2018	NS	0 ppt	<1,000 ppt	NT
Dichloroacetic Acid	2018	NS	0 ppt	5,375 ppt	NT
Monobromoacetic Acid	2018	NS	0 ppt	<1,000 ppt	NT
Monochloroacetic Acid	2018	NS	0 ppt	<2,000 ppt	NT
Trichloroacetic Acid	2018	NS	0 ppt	8,180 ppb	NT
		60,000 ppt		Total 13,940 ppt	No Standard

IV Radioactivity

			MDL		
Gross Alpha	2009	15 pCi/l	0 pCi/l	2.3	0.18 +/- 1.22 pCi/L
Gross Beta	2002	50 pCi/l	0 pCi/l	1.9	1.2 +/- 1.3 pCi/L
Radium 226	2009	20 pCi/l	0 pCi/l	0.53	0.02 +/- 0.23 pCi/L
Radium 228	2009	20 pCi/l	0 pCi/l	0.93	0.74 +/- 0.60
Uranium Total	2008	30 pCi/l	0 pCi/l	1.00	0.12 +/- 0.10

V Volatile Organic Compounds (VOCs)

Benzene	2017	5,000 ppt	1,000 ppt	<100 ppt	<500 ppt
Bromobenzene	2017	NS	NS	<100 ppt	<500 ppt
Bromochloromethane	2017	NS	NS	<100 ppt	<500 ppt
Bromodichloromethane	2017	NS	0 ppt	11 ppb	NT
Bromoform	2017	NS	NS	<200 ppt	NT
Bromomethane	2017	NS	NS	<400 ppt	<500 ppt
n-Butylbenzene	2011	NS	NS	<500 ppt	<500 ppt
sec-Butylbenzene	2011	NS	NS	<500 ppt	<500 ppt
tert-Butylbenzene	2011	NS	NS	<500 ppt	<500 ppt
Carbon Tetrachloride	2017	5,000 ppt	0 ppt	<100 ppt	<500 ppt
Chlorobenzene	2011	100,000 ppt	100,000 ppt	<500 ppt	<500 ppt
Chlorehthane	2017	NS	NS	<200 ppt	<500 ppt

V Volatile Organic Compounds (VOCs) continued

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
Chloroform	2017	NS	NS	19.0 ppb	NT
Chloromethane	2017	NS	NS	<200 ppt	<500 ppt
2-Chlorotoluene (o-)	2017	NS	NS	<100 ppt	<500 ppt
4-Chlorotoluene (p-)	2017	NS	NS	<100 ppt	<500 ppt
Dibromomethane	2017	5,000 ppt	NS	<100 ppt	<500 ppt
Dibromochloromethane	2017	NS	NS	3.3 ppb	NT
Dichloromethane (DCM)	2017	5,000 ppt	0 ppt	<200 ppt	<500 ppt
1, 3-Dichlorobenzene (m-)	2017	NS	NS	<100 ppt	<500 ppt
1, 2-Dichlorobenzene (o-)	2017	600 ppb	600 ppb	<100 ppt	<500 ppt
1, 4-Dichlorobenzene (p-)	2017	75 ppb	75 ppb	<100 ppt	<500 ppt
Dichlorodifluoromethane	2017	NS	NS	<200 ppt	<500 ppt
1,1-Dichloroethane	2017	NS	NS	<200 ppt	<500 ppt
1,2-Dichloroethane	2017	5,000 ppt	0 ppt	<100 ppt	<500 ppt
1, 1-Dichloroethylene	2017	7,000 ppt	7,000 ppt	<100 ppt	<500 ppt
1, 2-Dichloroethylene, cis	2017	70,000 ppt	70,000 ppt	<100 ppt	<500 ppt
1, 2-Dichloroethylene, trans	2017	100,000 ppt	100,000 ppt	<500 ppt	<500 ppt
1, 2-Dichloropropane	2017	5,000 ppt	0 ppt	<100 ppt	<500 ppt
1, 3-Dichloropropane	2017	NS	NS	<100 ppt	<500 ppt
1, 1-Dichloropropene	2017	NS	NS	<300 ppt	<500 ppt
2, 2-Dichloropropane	2017	NS	NS	<100 ppt	<500 ppt
1,1-Dichloropropylene	2017	NS	NS	<300 ppt	<500 ppt
1,3-Dichloropropylene, cis	2017	NS	NS	<100 ppt	<500 ppt
1,3-Dichloropropylene trans	2017	NS	NS	<100 ppt	<500 ppt
1, 3-Dichloropropene	2017	NS	NS	<500 ppt	<500 ppt
Ethylbenzene	2017	700,000 ppt	700,000 ppt	<100 ppt	<500 ppt
Hexachlorobutadiene	2017	NS	NS	<100 ppt	<500 ppt
Isopropylbenzene	2017	NS	NS	<100 ppt	<500 ppt
4-Isopropyltoluene	2017	NS	NS	<100 ppt	<500 ppt
Methyl-t-butyl ether (MTBE)	2017	NS	NS	<200 ppt	<500 ppt
Naphthalene	2017	NS	NS	<300 ppt	<500 ppt
Chlorobenzene	2017	100,000 ppt	100,000 ppt	<100 ppt	NT
n-Propylbenzene	2017	NS	NS	<100 ppt	<500 ppt
Styrene	2017	100,000 ppt	100,000 ppt	<200 ppt	<500 ppt
1,1,1, 2-Tetrachloroethane	2017	NS	NS	<100 ppt	<500 ppt

V Volatile Organic Compounds (VOCs) continued

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
1,1,2, 2-Tetrachloroethane	2017	NS	NS	<100 ppt	<500 ppt
Tetrachloroethylene (PCE)	2017	5,000 ppt	0 ppt	<300 ppt	<500 ppt
Toluene	2017	1,000,000 ppt	1,000,000 ppt	<100 ppt	<500 ppt
1,2, 3-Trichlorobenzene	2017	NS	NS	<300 ppt	<500 ppt
1,2, 4-Trichlorobenzene	2017	70,000 ppt	70,000 ppt	<300 ppt	<500 ppt
1,1, 1-Trichloroethane	2017	200,000 ppt	200,000 ppt	<100 ppt	<500 ppt
1,1, 2-Trichloroethane	2017	5,000 ppt	3,000 ppt	<100 ppt	<500 ppt
Trichloroethylene (TCE)	2017	5,000 ppt	0 ppt	<200 ppt	<500 ppt
Trichlorofluoromethane	2017	NS	NS	<100 ppt	<500 ppt
1,2, 3-Trichloropropane	2017	NS	NS	<100 ppt	<500 ppt
1,2,4-Trimethylbenzene	2017	NS	NS	<100 ppt	<500 ppt
1,2,5-Trimethylbenzene	2017	NS	NS	<100 ppt	<500 ppt
1,3,5-Trimethylbenzene	2017	NS	NS	<100 ppt	NT
Vinyl Chloride	2017	200 ppt	0 ppt	<200 ppt	<200 ppt
Xylene, Total	2017	10,000,000 ppt	10,000,000 ppt	<100 ppt	<500 ppt
m(1,3) & p(1,4) Xylene	2017	NS	NS	<200 ppt	<500 ppt
o(1,2)-Xylene	2017	NS	NS	<100 ppt	<500 ppt

VI Synthetic Organic Compounds (SOCs) and Pesticides, Herbicides and PCBs

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
Aalachlor (Lasso)	2017	2,000 ppt	0 ppt	<10 ppt	<200 ppt
Aldicarb, Total	2017	3,000 ppt	NS	<100 ppt	<500 ppt
Aldicarb Sulfone	2017	2,000 ppt	NS	<100 ppt	<400 ppt
Aldicarb Sulfoxide	2017	4,000 ppt	NS	<100 ppt	<500 ppt
Aldrin	2017	NS	NS	<10 ppt	<100 ppt
Atrazine	2017	3,000 ppt	3,000 ppt	0.04 ppb	<100 ppt
Benzo(a)pyrene (PAHs)	2002	200 ppt	0 ppt	<20 ppt	NT
Butachlor	2017	NS	NS	<10 ppt	<100 ppt
Carbaryl	2017	NS	NS	<100 ppt	<100 ppt
Carbofuran	2017	40,000 ppt	40,000 ppt	<10 ppt	<900 ppt
Chlordane alpha	1994	NS	NS	<100 ppt	NT

VI Synthetic Organic Compounds (SOCs) and Pesticides, Herbicides and PCBs continued

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
Chlordane gamma	1994	NS	NS	<100 ppt	NT
Chlordane	2011	2,000 ppt	0 ppt	<100 ppt	<100 ppt
2, 4-D	2017	70,000 ppt	70,000 ppt	<100 ppt	<100 ppt
Dalapon	2017	200 ppb	200 ppb	0.37 ppb	<1.0 ppb
1, 2-Dibromo-3-chloropropane (DBCP)	2011	200 ppt	0 ppt	<20 ppt	NT
Dicamba	2017	NS	NS	<100 ppt	<100 ppt
Dieldrin	2017	NS	NS	<20 ppt	<100 ppt
Di (2-ethylhexyl) adipate	2017	400,000 ppt	400,000 ppt	<600 ppt	NT
Di (2-ethylhexyl) phthalate	2017	6,000 ppt	0 ppt	<600 ppt	NT
2,3,7, 8-TCDD (Dioxin)	2014	30 ppq	0 ppq	<0.5 ppq	NT
Dinoseb	2017	7,000 ppt	7,000 ppt	<70 ppt	<100 ppt
Diquat	2017	20,000 ppt	20,000 ppt	<300 ppt	<400 ppt
Endothall	2017	100 ppb	100 ppb	<4.0 ppb	<9.0 ppb
Endrin	2017	2,000 ppt	2,000 ppt	<10 ppt	<10 ppt
Ethylene dibromide (EDB)	2011	50 ppt	0 ppt	<20 ppt	NT
Glyphosate (Round-up)	2017	700 ppb	700 ppb	<4.0 ppb	<6.0 ppb
Heptachlor	2017	400 ppt	0 ppt	<10 ppt	<40 ppt
Heptachlor epoxide	2017	200 ppt	0 ppt	<10 ppt	<20 ppt
Hexachlorobenzene	2017	1,000 ppt	0 ppt	<10 ppt	<100 ppt
Hexachlorocyclopentadiene (HEX)	2017	50,000 ppt	50,000 ppt	0.02 ppb	<100 ppt
3-Hydroxycarbofuran	2017	40 ppb	40 ppb	<0.1 ppb	<1.0 ppb
BHC Gamma (Lindane)	2017	200 ppt	200 ppt	<10 ppt	<20 ppt
Methoxychlor	2017	40,000 ppt	40,000 ppt	<100 ppt	<100 ppt
Methomyl	2017	NS	NS	<10 ppt	<500 ppt
Metolachlor (Dual)	2017	NS	NS	<10 ppt	<100 ppt
Metribuzin (Sencor)	2011	NS	NS	<10 ppt	<100 ppt
Oxamyl (Vydate)	2011	200 ppb	200 ppb	<0.1 ppb	<1.0 ppb
Pentachlorophenol	2011	1,000 ppt	0 ppt	<10 ppt	<40 ppt
Picloram (Tordon)	2011	500,000 ppt	500,000 ppt	<30 ppt	<100 ppt
Propachlor	2011	NS	NS	<10 ppt	<100 ppt
2,4, 5-TP (Silvex)	2011	50,000 ppt	50,000 ppt	<70 ppt	<100 ppt
Simazine	2011	4,000 ppt	4,000 ppt	<20 ppt	<70 ppt
Toxaphene	2011	3 ppb	0 ppb	<0.9 ppb	<1.0 ppb

VI Synthetic Organic Compounds (SOCs) and Pesticides, Herbicides and PCBs continued

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
<u>Polychlorinated Biphenyls (PCBs) :</u>					
Aroclor 1016	2017	500 ppt	0 ppt	<800 ppt	<800 ppt
Aroclor 1232	2017	500 ppt	0 ppt	<230 ppt	<230 ppt
Aroclor 1248	2017	500 ppt	0 ppt	<100 ppt	<100 ppt
Aroclor 1260	2017	500 ppt	0 ppt	<200 ppt	<200 ppt
Aroclor 1221	2017	500 ppt	0 ppt	<190 ppt	<190 ppt
Aroclor 1242	2017	500 ppt	0 ppt	<260 ppt	<260 ppt
Aroclor 1254	2017	500 ppt	0 ppt	<100 ppt	<100 ppt

VII Microbiological Contaminants

MCL: No more than 5% of the 50 monthly Tap samples can be Total Coliform Positive.

	<u>MCLG</u>	<u>2018 Tap Water Results</u>	<u>2018 Raw Water Results</u>
<u>Bacteria:</u>			
<u>Total Coliform Positive</u>	0.00%	0.0 in 964 tests	334 in 365 tests
<u>Escherichia Coliforms (E. coli.) Positive</u>	0.00%	0.0 in 964 tests	139 in 365 tests
	<u>MCL</u>	<u>MCLG</u>	<u>2018 Tap Water Results</u>
<u>Pathogenic Protoza:</u>			
<u>Cryptosporidium parvum</u>	0	0	0 in 12 tests
<u>Giardia lamblia</u>	0	0	0 in 12 tests

VIII Unregulated Contaminants

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
Acetochlor (herbicide)	2009	NS	NS	<1.0 ppb	<1.0 ppb
2,4-Dinitrotoluene (explosives)	2002	NS	NS	<2.0 ppb	<2.0 ppb
2,6-Dinitrotoluene (explosives)	2002	NS	NS	<2.0 ppb	<2.0 ppb
DCPA acid metaolites (herbicide)	2002	NS	NS	<1.0 ppb	<1.0 ppb
4,4'-DDE (insecticide)	2002	NS	NS	<0.8 ppb	<0.8 ppb
EPTC (herbicide)	2002	NS	NS	<1.0 ppb	<1.0 ppb
Molinate (herbicide)	2002	NS	NS	<0.9 ppb	<0.9 ppb
MTBE (gasoline additive)	2002	NS	NS	<5.0 ppb	<5.0 ppb
Nitrobenzene (dyes, drugs, herbi.)	2002	NS	NS	<10 ppb	<10 ppb
Terbacil (herbicide)	2002	NS	NS	<2.0 ppb	<2.0 ppb
Perchlorate (solid fuel rockets)	2002	NS	NS	<4.0 ppb	<4.0 ppb

IX UMCR2 Assessment Monitoring

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
Dimethoate	2010	NS	NS	<0.7 ppb	NT
2,2',4,4',5,5'-Hexambromobiphenyl (HBB)	2010	NS	NS	<0.7 ppb	NT
2,2',4,4',5,5'-Hexambromobiphenyl ether (BDE-153)	2010	NS	NS	<0.8 ppb	NT
2,2',4,4',5-Pentabromobiphenyl ether (BDE-99)	2010	NS	NS	<0.9 ppb	NT
2,2',4,4',6-Pentabromobiphenyl ether (BDE-100)	2010	NS	NS	<0.5 ppb	NT
Terbufos-sulfone	2010	NS	NS	<0.4 ppb	NT
2,2',4,4'-Tetrabromodiphenyl ether (BDE-47)	2010	NS	NS	<0.3 ppb	NT
1,3-Dinitrobenzene	2010	NS	NS	<0.8 ppb	NT
RDX (Hexahydro-1,3,5-trinitro-1,3,5-triazine)	2010	NS	NS	<1.0 ppb	NT
TNT (2,4,6-Trinitrotoluene)	2010	NS	NS	<0.8 ppb	NT

X UMCR2 Screening Survey

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Distribution System Results</u>
N-Nitrosodiethylamine (NDEA)	2010	NS	NS	<0.0050 ppb	<0.0050 ppb
N-Nitrosodimethylamine (NDMA)	2010	NS	NS	<0.0020 ppb	<0.0020 ppb
N-Nitrosodi-N-butylamine (NDBA)	2010	NS	NS	<0.0040 ppb	<0.0040 ppb
N-Nitrosodi-N-propylamine (NDPA)	2010	NS	NS	<0.0070 ppb	<0.0070 ppb
N-Nitrosomethylalkylamine (NMEA)	2010	NS	NS	<0.0030 ppb	<0.0030 ppb
N-Nitrosopyrrolidine (NPYR)	2010	NS	NS	<0.0020 ppb	<0.0020 ppb
Acetochlor ESA	2010	NS	NS	<1.0 ppb	NT
Acetochlor OA	2010	NS	NS	<2.0 ppb	NT
Alachlor ESA	2010	NS	NS	<1.0 ppb	NT
Alachlor OA	2010	NS	NS	<2.0 ppb	NT
Metolachlor ESA	2010	NS	NS	<1.0 ppb	NT
Metolachlor OA	2010	NS	NS	<2.0 ppb	NT

XI Pharmaceutically Active Compounds

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
Acetaminophen	2017	NS	NS	<0.005 ppb	NT
Acesulfame-K	2017	NS	NS	0.16 ppb	NT
Antipyrine	2017	NS	NS	<0.001 ppb	NT
Atenolol	2017	NS	NS	<0.001 ppb	NT
Azithromycin	2017	NS	NS	<0.005 ppb	NT
Bacitracin	2011	NS	NS	<1.0 ppb	NT
Bezafibrate	2017	NS	NS	<0.0005 ppb	NT
Caffeine	2017	NS	NS	<0.05 ppb	NT
Carbadox	2017	NS	NS	<0.005 ppb	NT
Carbamazepine	2017	NS	NS	<0.001 ppb	NT
Chloramphenicol	2017	NS	NS	<0.005 ppb	NT
Chlorotetracycline	2017	NS	NS	<0.005 ppb	NT
Ciprofloxacin	2017	NS	NS	<0.05 ppb	NT
Clofibric acid	2017	NS	NS	<0.0005 ppb	NT
Cotinine	2017	NS	NS	0.002 ppb	NT
DEET	2017	NS	NS	0.008 ppb	NT
Dexamethasone	2017	NS	NS	<0.005 ppb	NT
Diazepam	2017	NS	NS	<0.001 ppb	NT
Diclofenac	2017	NS	NS	<0.0005 ppb	NT
Dilantin	2017	NS	NS	<0.002 ppb	NT
Diltiazem	2017	NS	NS	<0.0001 ppb	NT
Doxycycline	2017	NS	NS	<0.05 ppb	NT
Enrofloxacin	2017	NS	NS	<0.05 ppb	NT
Erythromycin	2017	NS	NS	<0.001 ppb	NT
Fluoxetine (Prozac)	2017	NS	NS	<0.001 ppb	NT
Gemfibrozil	2017	NS	NS	<0.0005 ppb	NT
Ibuprofen	2017	NS	NS	<0.05 ppb	NT
Iopromide	2017	NS	NS	<0.05 ppb	NT
Lasalocid	2017	NS	NS	<0.001 ppb	NT
Levothyroxine (Synthroid)	2017	NS	NS	<0.002 ppb	NT
Lincomycin	2017	NS	NS	<0.0001 ppb	NT
Meprobamate	2017	NS	NS	<0.001 ppb	NT

XI Pharmaceutically Active Compounds continued

	Date of <u>Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Tap Water Results</u>	<u>Raw Water Results</u>
Monensin	2017	NS	NS	0.001 ppb	NT
Naproxen	2017	NS	NS	<0.002 ppb	NT
Narasin	2017	NS	NS	<0.001 ppb	NT
Nicotine	2017	NS	NS	<0.005 ppb	NT
Norfloxacin	2017	NS	NS	<0.05 ppb	NT
Oleandomycin	2017	NS	NS	<0.001 ppb	NT
Oxytetracycline	2017	NS	NS	<0.05 ppb	NT
Paraxanthine	2017	NS	NS	<0.005 ppb	NT
Penicillin G	2017	NS	NS	<0.002 ppb	NT
Pencillin V	2017	NS	NS	<0.002 ppb	NT
Prednisone	2017	NS	NS	<0.002 ppb	NT
Primidone	2017	NS	NS	<0.005 ppb	NT
Roxithromycin	2017	NS	NS	<0.001 ppb	NT
Salicylic acid	2017	NS	NS	<0.05 ppb	NT
Salinomycin	2017	NS	NS	<0.0001 ppb	NT
Simvastatin	2017	NS	NS	<0.005 ppb	NT
Sulfachloropyridazine	2017	NS	NS	<0.005 ppb	NT
Sulfadiazine	2017	NS	NS	<0.001 ppb	
Sulfadimethoxine	2017	NS	NS	<0.0001 ppb	NT
Sulfamerazine	2017	NS	NS	<0.001 ppb	NT
Sulfamethazine	2017	NS	NS	<0.001 ppb	NT
Sulfamethizole	2017	NS	NS	<0.001 ppb	NT
Sulfamethoxazole	2017	NS	NS	<0.001 ppb	NT
Sulfasalazine	2017	NS	NS	<0.005 ppb	NT
Sulfathiazole	2017	NS	NS	<0.001 ppb	NT
Sucratose	2017	NS	NS	0.038 ppb	NT
Tetracycline	2017	NS	NS	<0.5 ppb	NT
Theobromine	2017	NS	NS	<0.05 ppb	NT
Theophylline	2017	NS	NS	<0.005 ppb	NT
Triclocarban	2017	NS	NS	<0.005 ppb	NT
Triclosan	2017	NS	NS	<0.05 ppb	NT
Trimethoprim	2017	NS	NS	<0.001 ppb	NT
Tylosin	2017	NS	NS	<0.001 ppb	NT
Tris(2-chloroethyl) phosphate	2017	NS	NS	<0.01 ppb	NT
Tris(chloroethyl) phosphate	2017	NS	NS	0.01 ppb	NT
Virginiamycin M1	2017	NS	NS	<0.001 ppb	NT

XII UMCR3 Assessment Monitoring

	<u>Date of Last Test</u>	<u>MCL</u>	<u>MCLG</u>	<u>Range</u>	<u>Tap Water Results</u>	<u>Distribution System Results</u>
Chromium	2014	100 ppb	100 ppb	<.2-.2 ppb	.25 ppb	.2 ppb
Cobalt	2014	NS	NS	< 1 ppb	< 1 ppb	< 1 ppb
Molybdenum	2014	NS	NS	<1-1 ppb	1 ppb	1 ppb
Strontium	2014	NS	NS	110-120 ppb	125 ppb	120 ppb
Vanadium	2014	NS	NS	.3 ppb	.3 ppb	.3 ppb
Chromium, Hexavalent	2014	NS	NS	.19-.20 ppb	.21 ppb	0.2 ppb
Chlorate	2014	NS	NS	65-140 ppb	46 ppb	54 ppb
1,4-Dioxane	2014	NS	NS	< .07 ppb	NT	NT
Bromochloromethane	2014	NS	NS	< .06 ppb	NT	NT
Bromomethane	2014	NS	NS	< .2 ppb	NT	NT
1,3-Butadiene	2014	NS	NS	< .1 ppb	NT	NT
Chlorodifluoromethane	2014	NS	NS	< .08 ppb	NT	NT
Chloromethane	2014	NS	NS	< .2 ppb	NT	NT
1,1-Dichloroethane	2014	NS	NS	< .03 ppb	NT	NT
1,2,3-Trichloropropane	2014	NS	NS	< .03 ppb	NT	NT
Perfluorobutanesulfonic acid (PFBS)	2014	NS	NS	< .09 ppb	NT	NT
Perfluoroheptanoic acid (PFHpA)	2014	NS	NS	< .01 ppb	NT	NT
Perfluorohexanesulfonic acid (PFHxS)	2014	NS	NS	< .03 ppb	NT	NT
Perfluorononanoic acid (PFNA)	2014	NS	NS	< .02 ppb	NT	NT
Perfluorooctanesulfonic acid (PFOS)	2014	NS	NS	< .04 ppb	NT	NT
Perfluorooctanoic acid (PFOA)	2014	NS	NS	<.02 ppb	NT	NT

XIII Lead and Copper

	<u>Date of Last Test</u>	<u>MCL (Action Level)</u>	<u>MCLG</u>	<u>Distribution System 90th Percentile Results</u>
Lead	2017	15 ppb	0	7.5 ppb
Copper	2017	1300 ppb	1300 ppb	59 ppb

